

SERTIFIKAAT

CERTIFICATE

Nr 305-01/07



Product

Fire-resistant foam **TYTAN B1**.

Supplier

Selena Co. S.A. (NIP 894-00-05-523)
Ul. Powstańców Śląskich 95, 53-332 Wrocław, POLAND.

Manufacturer

Orion Sp.zo.o., Pieszycza 4, 58-200 Dzierżonów, POLAND.

Product description

Sealing of fire separating building elements made of concrete, lightweight concrete, bricks and masonry partition walls.

Classification standard

EVS-EN 13501-2:2004 "Fire classification of construction products and building elements – Part 2: Classification using data from fire resistance tests, excluding ventilation services".

Classification

Based on test results the fire resistant-foam **TYTAN B1** satisfies the criteria of the fire-resistance grade **EI 30 – EI 120**, according to associated documents.

Basis documents

1. Assessments report No. KK-10-07 (SB EstCert OÜ);
2. Decision of the Board No. 07/02/07, 28.02.2007;
3. Test report No. TV-10/03, 14.11.2003.a. (TNB).

Associated documents

1. Technical datasheet (appendix 1; 3 pages);
2. Fire resistant classification (appendix 2; 1 page);
3. Quality inspections register KJL-117/2007 R1.

Quality control

Quality control is carried out according to quality supervision contract No KJL-117/2007.

Certificate validity conditions

Present certificate is valid from 01.03.2007 and valid till 01.03.2012 on condition that regular manufacturing instruction supervision is performed in due time and according note is made in register. Current certificate is not certificate of conformity according to the construction product directive 89/106/EEC, and don't give authority to place CE-sign to the product.

Certificate additions 1 and 2 are certificate inseparable parts.

Janek Neltsas

Chief executive



PC 015 (EN 45011)
1 032 (EN 45004)

Sertifitseerimisbüroo EstCert OÜ
Reg nr 10952693
Laki 14a, 10621 Tallinn

Tel: 651 7797
Faks: 651 7796
e-post: info@estcert.ee